

Technical drawing of a fire alarm pull station (消火栓) showing dimensions and components.

Dimensions:

- Overall width: 900
- Overall height: 1400
- Top section width segments: 25, 275, 25, 550, 25
- Right section height segments: 25, 275, 25
- Bottom section height segments: 1050, 25
- Left section height segment: 1000

Labels and Components:

- アイラッチ** (Eye latch) - Located at the top of the main panel.
- * 火報部別図** (Fire alarm department separate drawing) - Located in the top right corner.
- 表示マーク** (Display mark) - Located in the middle right section.
- 消火栓** (Fire alarm pull station) - The main component, located in the middle right section.
- 消火器** (Fire extinguisher) - Located in the middle left section.
- ワンラッチ** (One-latch) - Located in the bottom left section.
- 裏面使用方法説明板貼付ケ** (Back use method instruction board attachment) - Located in the bottom right section.
- 消防章貼付** (Fire department stamp attachment) - Located at the bottom center.

消火栓	30×90°	起動スイッチ付	1ヶ
自動調整弁	30	静圧・動圧対応	1ヶ
ノズル	30	可変噴霧	1本
ホース	30×30m	保形	1本
ホース収納装置（PRスリム）			1組
認定評価型式番号: 認評栓第26～14号 [識別番号: IS1-PR209]			
使用圧力: 2.0MPa（締切圧） 圧力損失値: 0.28MPa（帝）			
放水口	65×90°		1ヶ
（裏配管）	65×180°		1ヶ

端子・ベル取付台 (H: 20)

Technical drawing of a cross-section of a bolted joint. The drawing shows a central hole with a diameter of 15 mm ($\phi 15$). The total width of the plate is 140 mm. The distance from the center of the hole to the right edge is 120.8 mm. The thickness of the plate is 10 mm. There are 6 M4 bolts. The distance between the center of the hole and the center of the first bolt is 67 mm. The total width of the bolted area is 250 mm.

[illegible]

890 (開口)

約 882 (天・底板外寸)

880

900 (露出型)

700

70

520

70

1363 (外寸)

1370 (開口)

通線孔

E3

材料	t 1.6 電気亜鉛めっき鋼板	65		40	65		40	40		65	40		65		
仕上	メラミン樹脂焼付塗装														
標示	シール文字	A		B		C		D		E		F			
標示	文字白色斜線部赤色 (消火器)														

承認	照査	製図

能美防災 (株) リング型 イ 薄型表示灯 ロ リング型 ハ リング型表示灯付発信機 薄型表示灯 専用金具 φ117.2 4-M4×12L 屏裏面スタッドビス φ50 2-M4タップ	ニッタン (株) フラット イ P L - F ロ フラット ハ 表示灯付フラット発信機 フラット表示灯 (*1=75) φ113 φ80	標準 (発信機 表示灯分離) タイプ イ ロ ハ IS標準 発信機 表示灯 パササイン Aタイプ (*1=75) φ81 105 4-φ4.5×19.5L φ58 2-φ5 φ80
ホーチキ (株) 注) 取付方法が2パターンあります。 フラット型 イ 表示灯 ロ フラット型 ハ フラット取付 表示灯 専用金具 φ117.2 4-M4タップ φ58 2-φ5	ホーチキ (株) 注) 取付方法が2パターンあります。 フラット型 イ 表示灯 ロ フラット型 ハ 表側取付 表示灯 2-M4タップ φ58 2-φ5	能美防災 (株) 小型発信機 表示灯 NNF70015 2-M4タップ φ108 ニッタン (株) フラット発信機 1MM1W-01 2MM1W-01 2-M4タップ φ124 パナソニック (株) or 日本ドライケミカル (株) 小型発信機 表示灯 NNF70015 2-M4タップ φ120
パナソニック (株) リング型 イ フラット型 ロ リング型 ハ フラット取付 表示灯 (フラット型) φ127 φ50 4-M4×15L 屏裏面スタッドビス φ50 2-M4タップ	日本ドライケミカル (株) 注) 取付方法が2パターンあります。 リング型 イ フラット型 ロ リング型 ハ 簡単取付 表示灯 (フラット型) φ120 φ50 2-M4タップ	横幅 (w1) 火報ピッチ (P) 550 150 700 200 図 火報一覧図 (横開き) 図 番 OFE26025-00 名 火報機器は別途となります。 製図日 2026年 6月 4日 承認 照査 製図 IS 益立堀製作所 益立堀 製作所